

Exhibit F

10/8/18 Letter



FILED Received for Filing Oakland County Clerk 10/17/2018 10:37 AM

PRINCIPALS
Daniel W. Mitchell
Nancy M. D. Faught
Keith D. McCormack
Jesse B. VanDeCreek
Roland N. Alix
Michael C. MacDonald
James F. Burton
Charles E. Hart
Todd J. Sneathen

CONTROLLER
Donna M. Martin

SENIOR ASSOCIATES
Gary J. Tressel
Randal L. Ford
William R. Davis
Dennis J. Benoit
Robert F. DeFrain
Thomas D. LaCross
Albert P. Mickalich
Timothy H. Sullivan
Thomas G. Maxwell

ASSOCIATES
Marshall J. Grazioli
Colleen L. Hill-Stramsak
Bradley W. Shepler
Karyn M. Stickel
Jane M. Graham
Aaron A. Uranga
Salvatore Conigliaro
Melissa A. Coatta
Michael P. Darga
Brian K. Davies
Matthew G. Slicker
James J. Surhigh
Trevor S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.
STREET: 105 W. Grand River
Howell, MI 48843
PHONE: 517-552-9199
WEBSITE: hrcengr.com

OTHER OFFICE LOCATIONS
Bloomfield Hills
Delhi Township
Detroit
Grand Rapids
Jackson
Kalamazoo
Lansing

October 8, 2018
Milford Township
1100 Atlantic Street
Milford, MI 48381

Attn: Tim Brandt, Building and Zoning Official

Re: Drainage Plan Review – 2nd Review
2610 Pearson Road

HRC Job No. 20180833.02

Dear Mr. Brandt:

Our office was directed by Milford Township to re-review the proposed fill and grading plans submitted to the Township Board on September 19, 2018, in support of a permit application for the property located at 2610 Pearson Road. Our initial review of this matter, dated August 24, 2018, solely addressed the Boss Engineering grading plan, dated August 14, 2018, that was submitted by the applicant. As a result of discussion that occurred at the subject Board meeting, and through subsequent review of related materials, it appears that certain pre-development conditions may have been different than originally presented by the applicant. As such, our office recommends the Township approve the requested Fill and Grade Permit conditioned upon the following:

1. The applicant must submit to the Township a drainage area map showing the entire tributary area to 2610 Pearson Road, determine the retention volume created by a 10-year storm and calculate the preconstruction area of the low spot that contained this volume. This information can be used to determine if additional retention volume needs to be provided with the proposed grading plan and if additional topographic information needs to be shown on the adjacent properties.
2. The applicant must improve the proposed swales, according to Township standards, to divert water from behind the home to the low area. It appears that the current site grading may be impeding the flow of water from the east and not allowing it to make it to the low area.
3. The plans should include calculations to verify that any proposed culvert is properly sized to facilitate drainage to the low point west of the driveway.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.

Michael P. Darga
Michael P. Darga, PE

MPD/mpd
pc: Millford Twp; D. Green, R. Tessman
HRC; R. Alix, File