

Exhibit D

8/24/18 Letter



FILED Received for Filing Oakland County Clerk 10/17/2018 10:37 AM

- PRINCIPALS**
 Daniel W. Mitchell
 Nancy M.D. Faught
 Keith D. McCormack
 Jesse B. VanDeCreek
 Roland N. Alix
 Michael C. MacDonald
 James F. Burton
 Charles E. Hart
 Todd J. Sneathen
- CONTROLLER**
 Donna M. Martin
- SENIOR ASSOCIATES**
 Gary J. Tressel
 Randal L. Ford
 William R. Davis
 Dennis J. Benolt
 Robert F. DeFraim
 Thomas D. LaCross
 Albert P. Mickalich
 Timothy H. Sullivan
 Thomas G. Maxwell
- ASSOCIATES**
 Marshall J. Grazioli
 Colleen L. Hill-Stramsak
 Bradley W. Shepler
 Karyn M. Sticker
 Jane M. Graham
 Aaron A. Uranga
 Salvatore Conigliaro
 Melissa A. Coatta
 Michael P. Darga
 Brian K. Davies
 James E. Scholl
 Matthew G. Slicker
 James J. Surhugh
 Trevor S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.
 STREET: 105 W. Grand River
 Howell, MI 48843
 PHONE: 517-552-9199
 WEBSITE: hrcengr.com

- OTHER OFFICE LOCATIONS**
 Bloomfield Hills
 Delhi Township
 Detroit
 Grand Rapids
 Jackson
 Kalamazoo
 Lansing

August 24, 2018

Milford Township
 1100 Atlantic Street
 Milford, MI 48381

Attn: Tim Brandt, Building and Zoning Official

Re: Drainage Plan Review
 2610 Pearson Road

HRC Job No. 20180833.02

Dear Mr. Brandt:

As requested, this office has reviewed the proposed grading plan for a residential driveway prepared by Boss Engineering (dated August 14, 2018). It is our understanding that the location of the driveway is in a low area and is prone to flooding.

The plans indicate that the driveway will require 780 cyd of fill in this area and a new low area is proposed to be excavated along the west side of the driveway providing 890 cyd of volume. Therefore, the proposed volume of the low area has not been reduced within the boundaries of the residential property. It can be assumed that any flooding that occurs post development should be similar to the flooding elevations predevelopment (ignoring the slight change in impervious area of the home). This office does not object to the proposed grading plan.

It is noted that we are assuming that the existing contours on the plan are from the predevelopment of the property and accurately reflect the predevelopment conditions.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.

Michael P. Darga
 Michael P. Darga, PE

MPD/mpd

pc: Milford Twp; D. Green, R. Tessman
 HRC; R. Alix, File