


# **EXHIBIT 2**



HUBBELL, ROTH & CLARK, INC  
CONSULTING ENGINEERS SINCE 1915

PRINCIPALS

Daniel W. Mitchell  
Nancy M.D. Faught  
Kelth D. McCormack  
Jesse B. VanDeCreek  
Roland N. Alix  
Michael C. MacDonald  
James F. Burton  
Charles E. Hart  
Todd J. Sneathen

CONTROLLER

Donna M. Martin

SENIOR ASSOCIATES

Gary J. Tressel  
Randal L. Ford  
William R. Davis  
Dennis J. Benoit  
Robert F. DeFrain  
Thomas D. LaCross  
Albert P. Mickalich  
Timothy H. Sullivan  
Thomas G. Maxwell

ASSOCIATES

Marshall J. Grazioli  
Colleen L. Hill-Stramsak  
Bradley W. Shepler  
Karyn M. Stickel  
Jane M. Graham  
Aaron A. Uranga  
Salvatore Conigliaro  
Melissa A. Coatta  
Michael P. Darga  
Brian K. Davies  
James E. Scholl  
Matthew G. Slicker  
James J. Surhigh  
Trevor S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.  
STREET: 105 W. Grand River  
Howell, MI 48843  
PHONE: 517-552-9199  
WEBSITE: hrcengr.com

OTHER OFFICE LOCATIONS

Bloomfield Hills  
Delhi Township  
Detroit  
Grand Rapids  
Jackson  
Kalamazoo  
Lansing

August 24, 2018

Milford Township  
1100 Atlantic Street  
Milford, MI 48381

Attn: Tim Brandt, Building and Zoning Official

Re: Drainage Plan Review  
2610 Pearson Road

HRC Job No. 20180833.02

Dear Mr. Brandt:

As requested, this office has reviewed the proposed grading plan for a residential driveway prepared by Boss Engineering (dated August 14, 2018). It is our understanding that the location of the driveway is in a low area and is prone to flooding.

The plans indicate that the driveway will require 780 cyd of fill in this area and a new low area is proposed to be excavated along the west side of the driveway providing 890 cyd of volume. Therefore, the proposed volume of the low area has not been reduced within the boundaries of the residential property. It can be assumed that any flooding that occurs post development should be similar to the flooding elevations predevelopment (ignoring the slight change in impervious area of the home). This office does not object to the proposed grading plan.

It is noted that we are assuming that the existing contours on the plan are from the predevelopment of the property and accurately reflect the predevelopment conditions.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.

Michael P. Darga, PE

MPD/mpd

pc: Milford Twp; D. Green, R. Tessman  
HRC; R. Alix, File

FILED Received for Filing Oakland County Clerk 10/17/2018 10:37 AM