

**Exhibit K**

**10/8/18 HRC Letter**



PRINCIPALS

Daniel W. Mitchell  
Nancy M. D. Faught  
Keith D. McCormack  
Jesse B. VanDeCreek  
Roland N. Aik  
Michael C. MacDonald  
James F. Burton  
Charles E. Hart  
Todd J. Snelhen

CONTROLLER  
Dorva M. Martin

SENIOR ASSOCIATES

Gary J. Tressel  
Randal L. Ford  
William A. Davis  
Dennis J. Gerolt  
Robert F. DeFrain  
Thomas D. LaCross  
Albani P. Mickalich  
Timothy H. Sullivan  
Thomas G. Maxwell

ASSOCIATES

Marshall J. Grazjoll  
Colleen L. H. Stramsak  
Bradley W. Shepler  
Karyn M. Slickel  
Jane M. Graham  
Aaron A. Uranga  
Salvatore Conigliaro  
Melissa A. Cozta  
Michael P. Oarga  
Brian K. Davies  
Matthew G. Slicker  
James J. Surligh  
Travis S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.  
STREET: 105 W. Grand River  
Howell, MI 48843  
PHONE: 517-552-9199  
WEBSITE: hrceng.com

OTHER OFFICE LOCATIONS  
Bloomfield Hills  
Dahli Township  
Detroit  
Grand Rapids  
Jackson  
Kalamazoo  
Lansing

October 8, 2018

Milford Township  
1100 Atlantic Street  
Milford, MI 48381

Attn: Tim Brandt, Building and Zoning Official

Re: Drainage Plan Review - 2nd Review  
2610 Pearson Road

HRC Job No. 20180833.02

Dear Mr. Brandt:

Our office was directed by Milford Township to re-review the proposed fill and grading plans submitted to the Township Board on September 19, 2018, in support of a permit application for the property located at 2610 Pearson Road. Our initial review of this matter, dated August 24, 2018, solely addressed the Boss Engineering grading plan, dated August 14, 2018, that was submitted by the applicant. As a result of discussion that occurred at the subject Board meeting, and through subsequent review of related materials, it appears that certain pre-development conditions may have been different than originally presented by the applicant. As such, our office recommends the Township approve the requested Fill and Grade Permit conditioned upon the following:

1. The applicant must submit to the Township a drainage area map showing the entire tributary area to 2610 Pearson Road, determine the retention volume created by a 10-year storm and calculate the preconstruction area of the low spot that contained this volume. This information can be used to determine if additional retention volume needs to be provided with the proposed grading plan and if additional topographic information needs to be shown on the adjacent properties.
2. The applicant must improve the proposed swales, according to Township standards, to divert water from behind the home to the low area. It appears that the current site grading may be impeding the flow of water from the east and not allowing it to make it to the low area.
3. The plans should include calculations to verify that any proposed culvert is properly sized to facilitate drainage to the low point west of the driveway.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.

*Michael P. Oarga*  
Michael P. Oarga, PE

MPD/mpd

cc: Milford Twp; D. Green, R. Tessman  
HRC; R. Aik, File

FILED Received for Filing Oakland County Clerk 10/17/2018 10:37 AM