


Exhibit D

8/24/18 Letter



HUBBELL, ROTH & CLARK, INC
CONSULTING ENGINEERS SINCE 1915

PRINCIPALS

- Daniel W. Mitchell
- Nancy M. D. Faught
- Keith D. McCormack
- Jesse B. VanDeCreek
- Roland N. Alix
- Michael C. MacDonald
- James F. Burton
- Charles E. Hart
- Todd J. Sneathen

CONTROLLER

- Donna M. Martin

SENIOR ASSOCIATES

- Gary J. Tressel
- Randal L. Ford
- William R. Davis
- Dennis J. Benolt
- Robert F. DeFrain
- Thomas D. LaCross
- Albert P. Mickalich
- Timothy H. Sullivan
- Thomas G. Maxwell

ASSOCIATES

- Marshall J. Grazloli
- Colleen L. Hill-Stramsak
- Bradley W. Shepler
- Karyn M. Stickel
- Jane M. Graham
- Aaron A. Uranga
- Salvatore Conigliaro
- Melissa A. Coatta
- Michael P. Darga
- Brian K. Davies
- James E. Scholl
- Matthew G. Slicker
- James J. Surhigh
- Trevor S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.
 STREET: 105 W. Grand River
 Howell, MI 48843
 PHONE: 517-552-9199
 WEBSITE: hrcengr.com

OTHER OFFICE LOCATIONS

- Bloomfield Hills
- Dethl Township
- Detroit
- Grand Rapids
- Jackson
- Kalamazoo
- Lansing

August 24, 2018

Milford Township
 1100 Atlantic Street
 Milford, MI 48381

Attn: Tim Brandt, Building and Zoning Official

Re: Drainage Plan Review
 2610 Pearson Road

HRC Job No. 20180833.02

Dear Mr. Brandt:

As requested, this office has reviewed the proposed grading plan for a residential driveway prepared by Boss Engineering (dated August 14, 2018). It is our understanding that the location of the driveway is in a low area and is prone to flooding.

The plans indicate that the driveway will require 780 cyd of fill in this area and a new low area is proposed to be excavated along the west side of the driveway providing 890 cyd of volume. Therefore, the proposed volume of the low area has not been reduced within the boundaries of the residential property. It can be assumed that any flooding that occurs post development should be similar to the flooding elevations predevelopment (ignoring the slight change in impervious area of the home). This office does not object to the proposed grading plan.

It is noted that we are assuming that the existing contours on the plan are from the predevelopment of the property and accurately reflect the predevelopment conditions.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.

Michael P. Darga
 Michael P. Darga, PE

MPD/mpd

pc: Milford Twp; D. Green, R. Tessman
 HRC; R. Alix, File

FILED Received for Filing Oakland County Clerk 10/17/2018 10:37 AM